

Approval Number: 1511521
Test Report: MAT/LAB 741Ja



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

7th December 2015

Interplast SA
10th KM National Road THessaloniki,
Katarni,
PO Box 62,
57400 Sindos,
Thessaloniki

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE - COMPONENTS.

5260

`Aqua-Plus Fiberglass triple layered PP Pipe`. Extruded, triple layered pipe consisting of a green coloured, polypropylene inner layer, off-white coloured glass fibre middle layer and green coloured, polypropylene outer layer. For use with water up to 70°C.

APPROVAL NUMBER: 1511521

APPROVAL HOLDER: INTERPLAST SA

The Scheme reserves the right to review approval.

Approval 1511521 is valid between November 2015 and November 2020

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme